

# Utah Department of Environmental Quality

## Division of Drinking Water

### Public Water System Inventory Report

Run Date:  
08/04/2011 12:05 pm

**PWS ID:** UTAH12002      **Name:** MONA TOWN WATER SYSTEM

**Legal Contact:** MONA      **Rating:** Approved  
 ALLEN R PAY      **Rating Date:** 10/08/1985

**Address:** 50 W CENTER #69      **Activity Status:** Active  
 MONA, UT 84645

**Phone Number:** 435-623-4913

**City Served (Area):**

**County:** JUAB COUNTY

**System Type:** Community      **Last Inv Update:** 06/17/2009      **Avg Daily Prod:**  
**Activity Status Cd:** Active      **Last Snty Srv Dt:** 08/12/2010      **Total Dsgn Cap:**  
**Population:** 1,400      **Surveyor:** JESSE A. JOHNSON      **Total Emerg Cap:**  
**Oper Period:** 1/1 to 12/31

**Gal/Day    Gal/Min**

### Contacts

Contact Type	Name	Title	Office Phone Numbers	Emergency	Email Address
AC	PAY, ALLEN R		435-623-4913	435-660-1098	MONACITY@NEBONET.CC

### Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Unknown	0	254
			254 Total Svc Connections

### Storage

**Total Storage:** 750,000 GAL      **Number of Units:** 3      **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	250,000 GAL	Ground	250,000 GAL	Concrete		A	NO
ST002	150,000 GAL TANK	Ground	150,000 GAL	Concrete		A	NO
ST003	350K STORAGE	Ground	350,000 GAL	Concrete		A	NO

### Distribution System

Pump Type	Total Dyn Head ft H2O    P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

### Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	UPPER CLOVER SPRING	Active	SP				Yes	GW	Permanent	1/1 to 12/31	
WS002	VEST SPRINGS	Inactive	SP				Yes	GW	Other		
WS003	MONA WELL 1	Inactive	WL				Yes	GW	Other		

*\*Reports measured flow for wells, approved design capacity for all other sources.*